



State of Ohio Environmental Protection Agency

**PHYSICAL ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 15, 2010

Jerry Brems  
Licking County  
20 South Second Street  
Newark, OH 43055

**Re: Construction Storm Water Inspection at Etna Parkway / Licking County  
Permit Number: 4GC03129\*AG**

Dear Mr. Brems:

This letter is written regarding the storm water inspection I conducted at Etna Parkway located between US 40 & State Route 16 in Pataskala, Ohio on August 27, 2010. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Control:**

- The majority of the site is currently paved
- All ditch checks must be maintained
- All ditches must be seeded and mulched prior to the onset of the winter months
- Large stockpiles on south end of the project must be protected from erosion prior to onset of winter months

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Etna Parkway 8-27-10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

