



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Paul Ryan  
Columbus Regional Airport Authority  
7161 Second Street  
Columbus, OH 43217

**Re: Construction Storm Water Inspection at Rickenbacker Parkway – Phase 2A / Franklin County  
Permit Number 4GC03205\*AG**

Dear Mr. Ryan:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Stephen Riley of Ohio EPA at Rickenbacker Parkway – Phase 2A located on "A" Avenue from Lockbourne Eastern Road to Port Road in Columbus, Ohio on August 25, 2010. The agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. The following items were noted:

**Sediment and Erosion Controls:**

- The silt fence located on site adjacent to the nearby stream was damaged and will require maintenance at this time. Corrective measures are expected within three days from receipt of this letter (See Figure 1).

**Maintenance:**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Rickenbacker Parkway Phase 2A

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

