



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Ed Den-Haan  
Ralph Fallon Builders Inc.  
5755 Zarley Street  
New Albany OH 43054

**Re: Construction Storm Water Inspection at Medors Residence/ Licking County.  
Permit Number 4GC03233\*AG**

Dear Mr. Den-Haan,

This letter is written in follow-up to a construction storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at **Medors Residence** located at 5920 Dutch Lane Road in Johnstown, Ohio on August 23, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The silt fence located along the western end of the project must be entrenched to ensure a proper functioning condition. Corrective measures are expected within three days from receipt of this letter.
- During the inspection our staff observed sediment laden water from the dewatering activities is diverted into the adjacent stream located on the western end of the project. Please ensure future dewatering activities do not result in turbid disturbances to waters of the state.

**Maintenance:**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on-site for the agency to review.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

*Ohio EPA is an Equal Opportunity Employer*



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Mike Allen  
Menard Inc.  
5101 Menard Drive  
Eau Claire, WI 54703

**Re: Construction Storm Water Inspection at Menards-Columbus North / Franklin County  
Permit Number: 4GC03213\*AG**

Dear Mr. Allen:

This letter is written regarding a storm water inspection conducted by Megan Reising and Stephen Riley of the Ohio EPA at Menards-Columbus North located at 1819 Morse Road in Columbus, Ohio on August 19, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment Erosion Controls:**

- The sediment and erosion controls at this site are currently functioning properly. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor DSW/CDO

HK/nsm Menards Columbus North 8-23-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



