



State of Ohio Environmental Protection Agency

STREET ADDRESS:

W. Zazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Mike Murray  
313 North State Street  
Westerville OH 43082

**Re: Construction Storm Water Inspection at St. Paul Athletic Field Complex Delaware County  
Permit Number: 4GC03137\*AG**

Dear Mr. Murray:

This letter is written regarding a storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at St. Paul Athletic Field Complex located at 195 Moss Road in Westerville, Ohio on August 24, 2010. Ohio EPA has received and approved this site for coverage under the General Storm Water Permit associated with Construction Activities. During the inspection, the following items were noted.

**Sediment and Erosion Controls:**

- It appears the construction at the site is scheduled to start in near future. Please ensure all sediment and erosion controls are addressed in compliance with the conditions of your General Storm Water Permit.

**Maintenance Requirements:**

- The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm St. Paul Athletic Field Complex 8-24-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

