



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 9, 2010

Charles Driscoll
Nelson Farms Associates Inc
495 South High Street #150
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Nelson Farms Sections 1, 2 and 3
Delaware County
Permit Number: 4GC01352*AG**

Dear Mr. Driscoll:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Vinod Tujalpuram of the Ohio EPA at Nelson Farms located on State Route 315, north of Home Road and East of Liberty Road in Liberty Township on August 24, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Most of the inlet protection boxes in the barren area appear to working as intended, but sediment appears to have breached these inlet protections on several of the catch basins. Please continue to conduct your weekly inspections to ensure that they remain in good condition.
- The orange and black catch basin protections do not appear to be adequately controlling sediment, as there are large amounts of sediment visible inside of these structures, particularly in the ones near the barren area (See Figure 1). Please install a more effective type of inlet protection suitable for the drainage areas.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Nelson Farms Sections 1,2, &3 8-24-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





Nelson Farms Phase 1, 2 & 3
Olentangy River Watershed

Photo by: Vinod Tujalpuram/Abigail Tamkin
Date: 08-24-2010



Figure 1: Note muddy grate inside of inlet protection

