



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Brian Boyd  
Joe Dirt  
2410 Performance Way  
Columbus, Ohio 43207

**Re: Construction Storm Water Inspection at Windsor Avenue Parcel D10-263045 / Franklin County.  
Permit Number: 4GC02992\*AG**

Dear Mr. Boyd:

This letter is written regarding the storm water inspection conducted by Stephen Riley and Megan Reising of Ohio EPA at Windsor Avenue Parcel D10-263045 located 1000 Feet East of Intersection of Joyce and Winsor Road, Columbus on August 19, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

**Sediment and Erosion Controls:**

- The silt fence must be established along the perimeters of the project.
- Please ensure all stockpiles located on the site are protected from erosion to meet the requirements of your General Permit.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

**Post Construction Requirements:**


- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Brian Boyd  
Joe Dirt  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Windsor Ave ;Parcel D10-263045, 8-19-2010