



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 2, 2010

Paul Mathews  
Liberty Union – Thurston Local School District  
621 Washington Street  
Baltimore, OH 43105

**Re: Construction Storm Water Inspection at Liberty Union High School  
Fairfield County  
Permit Number 4GC03102\*AG**

Dear Mr. Hilborn:

This letter is written in follow-up to a construction storm water inspection by Stephen Riley, of the Ohio EPA, conducted at Liberty Union High School located at 500 Washington Street on August 24, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. It appeared during the inspection that construction activity is completed for this site. A Notice of Termination will be required provided the following requirements are met.


- During the inspection our staff noticed sediment that has moved offsite and onto Washington Street. Please implement controls immediately to ensure compliance with the General Storm Water Permit.
- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Paul Mathews  
Liberty Union – Thurston Local School District  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Liberty Union High School 8-24-201