



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 2, 2010

Toby Shamblin
City of Lancaster Transportation Department
815 Lawrence Street
Lancaster, OH 43130

**Re: Pre-Construction Storm Water Inspection at City of Lancaster Salt Storage Facility / Fairfield County
Permit: 4GC03127*AG**

Dear Mr. Shamblin:

This letter is written regarding a storm water inspection conducted by Stephen Riley of the Ohio EPA at the City of Lancaster Salt Storage Facility located on Lawrence Street on August 24, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The silt fence on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Your Municipal Separate Storm Sewer System (MS4) permit requires the development of a Storm Water Pollution Prevention Plan (SWPPP) associated with the operations at this site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. All actions I have listed above require correction within three days from receipt of this letter unless otherwise noted.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm City of Lancaster Salt Storage Facility 8-24-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

