



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 2, 2010

Jim Szabo
Big Walnut Local Schools
70 North Walnut Street – Po Box 218
Galena, OH 43021

**Re: Construction Storm Water Inspection at Big Walnut Middle Schools/ Delaware
Permit: 4GC03148*AG**

Dear Mr. Szabo:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at **Big Walnut Middle Schools**, located on 777 Cheshire Road in Sunbury, Ohio on August 24, 2010. The agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. The following items were noted:

Sediment and Erosion Controls:

- Inlet protections located on-site are seen open and were not covered properly to minimize sediment runoff into the storm sewers. Corrective measures are expected within three days from receipt of this letter.

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Big Walnut Middle School 8-24-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



