



State of Ohio Environmental Protection Agency

RECEIPT ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 2, 2010

Steve Geiger
Geiger Excavating Inc
65 Southwind Drive
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Bedford II Landfill Cover
Franklin County.
Permit Number: 4GC03047*AG**

Dear Mr. Geiger:

This letter is written regarding the storm water inspection conducted by Stephen Riley and Abigail Tamkin of Ohio EPA at **Bedford II Landfill Cover** located at Enterprise Drive in Gahanna, Ohio on August 18, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- Our staff noted the skimmer in the sediment basin is overburdened with sediment (Figure 1). The basin is more than 50% full and in accordance with your permit must be cleaned to original design capacity within 10 days from receipt of this letter.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm Bedford II Landfill Cover, 8-18-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director






Figure 1: Retention pond in need of maintenance

