



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3896
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 1, 2010

Steven Legg
Anchor Cardinal Park Development LLC
8 East Long Street 3rd Floor
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Anchor Recycling 2
Franklin County
Permit Number: 4GC02961*AG**

Dear Mr. Legg:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of the Ohio EPA at Anchor Recycling 2 located at 453 Clay Craft Road in Columbus, Ohio on August 12, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- The silt fence located along the tributary on the northern end of the project site was impacted by stock piling of dirt. Corrective measures are expected within three days from receipt of this letter.
- The timeframe for the installation of sediment ponds at this site has passed. Sediment pond must be installed within 14 days from receipt of this letter to avoid the potential of escalated enforcement.

Maintenance:

- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO