



State of Ohio Environmental Protection Agency

RECEIPT ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 30, 2010

Chris Setzer  
Ohio Wesleyan University  
61 South Sandusky Street  
Delaware OH 43015

**Re: Construction Storm Water Inspection at Ohio Wesleyan Meek Aquatics & Recreation Center /Delaware County.  
Permit Number: 4GC03035\*AG**

Dear Mr. Setzer:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram of Ohio EPA, at **Ohio Wesleyan Meek Aquatics and Recreation Center** located at 150 South Henry Street in Delaware, Ohio on August 16, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

**Sediment and Erosion Controls:**

- The inlet protections located on the site are not covered properly to minimize sediment runoff into the storm sewer systems. Please ensure storm water discharges into the sewer systems would not result in turbid disturbances to the surface waters of the state.
- Silt fence located on the northeast end of the project site will require maintenance at this time. Corrective measures are expected within three days from receipt of this letter.
- Please ensure pond elevations and discharge structures are implemented in accordance with the approved plan.

**Maintenance**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CEDO