



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 30, 2010

Brad Jones
ODOT District 6
400 East William Street
Delaware, OH 43015

**Re: Construction Storm Water Inspection at MAD-40-1496 / Madison County.
Permit Number: 4GCD00061*AG**

Dear Mr. Jones:

This letter is written regarding the storm water inspection; I conducted at MAD-40-1496 located at US 40 at State Route 142 and County Road 7 in West Jefferson, Ohio on July 27, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment Erosion Controls:

- The entire site drains to a centralized sediment basin located on the northwest corner of the project. The basin has been sized according to the criteria mentioned in the General Storm Water Permit. The basin appears to be functioning as intended and must be maintained via your self-inspection reports every seven days or within 24 hours of precipitation event greater than 0.5 inches.
- Please ensure all barren areas are properly protected from erosion in preparation of the upcoming winter months.
- Please ensure the inlet protections are constructed and maintained in accordance with the ODOT Land and Design Manual.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, CDO/DSW

HK/nsm MAD 40-1496 7-27-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



3 1975 100 00 50 000