



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 20, 2011

Steve Fulkert  
M.H. Murphy Development Group  
4393 Arbor Lake Drive  
Groveport, OH 43125

**Re: Winchester Bend, Franklin County**

Dear Mr. Fulkert:

This letter is written regarding the storm water inspection that I conducted at Winchester Bend located near the intersection of Winchester Pike and Hamilton Road, in Columbus, Ohio. The inspection was conducted on June 13, 2011, as a follow-up to a previous inspection. I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed.

**Sediment and Erosion Controls:**

1. Perimeter silt fencing was installed, however there were a few small sections that needed to be maintained. You stated that you would have the silt fence repaired soon.
2. Please be aware that the general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
3. Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated.

Steve Fulkert  
M.H. Murphy Development Group  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

A handwritten signature in black ink, appearing to read 'G L Sanders', written in a cursive style.

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, CDO/DSW

GS/nsm Winchester Bend, June 13, 2011