



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

SIGNATURE RECEIVED

6/10/11

Certified Mail #91 7108 2133 3932 1838 4967

June 7, 2011

Jim Robinson  
Peregrine Health Services  
1661 Old Henderson Road  
Suite 400  
Columbus, OH 43220

**Re: Notice of Violation  
Echo Manor Nursing & Rehabilitation Center / Fairfield County  
Construction Storm Water General Permit #4GC03451\*AG**

Dear Mr. Robinson:

This letter is written regarding the storm water inspection I conducted of the construction activities at Echo Manor Nursing and Rehabilitation Center, located at 10270 Blacklick-Eastern Road NW, on June 3, 2011. The site had active construction during my site inspection. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Please consider this a formal notice of violation. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

The project site had several large barren areas without erosion controls. Sediment was discharging to the road due to a lack of erosion controls. Please install erosion controls around barren areas and maintain the existing dandy bags on the storm water drains. Please see attached pictures.

There were several barren areas that did not have recent construction activity or appeared to be at final grade. Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated. Please see attached pictures.

The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Chris Weible  
Village Communities  
Page -2-

There were several large oil and grease stains on the road that appear to be from leaking machinery. Please maintain machinery to prevent oil and grease discharging to the road. Any oil and grease spills should be immediately cleaned-up.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,



Gregory L. Sanders  
Environmental Specialist  
Stormwater Section  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

GLS/nsm Echo Manor Nursing Center, June 3, 2011