



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



March 7, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Dennis B. Brophy  
Allen Park Mobile Court  
15685 SW 116th, 109,  
King City, Oregon 97224-2695

Ottawa County  
Allen Park Mobile Court  
Community PWS

PWS ID: OH6204112

Dear Mr. Brophy:

The Division of Drinking and Ground Waters (DDAGW) Plant – Distribution Monthly Operating Report (MOR) for the month of January 2012, was received by the Ohio EPA-Northwest District Office (NWDO) as required on February 1, 2012.

Review of the December 2011 MOR indicates that the analytical result (0.412 mg/L) for iron exceeds the secondary maximum contaminant level (MCL). The Ohio Administrative Code (OAC) rule 3745-82-02 establishes the secondary MCL at (0.3 mg/L) for iron. OAC rule 3745-91-09 requires provision of treatment for removal of iron when an excessive amount of this substance is present in the untreated water. Consider the following items to determine why the standard is not being met:


1. Review the sampling location and technique used (i.e. was the sample pulled too soon after backwash events?)
2. Review the operation/maintenance of the filtering units (i.e. what is the head loss across the whole unit, is the filter media cemented or is channeling of the media occurring?)
3. Provide additional units/new equipment, or change treatment sequence. \*

**\* Note:** *Plan approval by this agency is required whenever a substantial change is made to the water system.*

Mr. Dennis B. Brophy  
March 7, 2012  
Page 2

If you have any questions regarding this letter, or any other matter involving your PWS, then contact me directly by telephone at (419) 373-3088 or via electronic messaging at [jack.schwartz@epa.state.oh.us](mailto:jack.schwartz@epa.state.oh.us).

Sincerely,



John A. (Jack) Schwartz  
Environmental Specialist 2  
Public Drinking Water Unit  
Division of Drinking and Ground Waters

JAS/llr

pc: Lorell Anderson, Park Manager  
Zach Danzer, Maintenance Manager  
Joseph L. St. Clair, Operator  
Ottawa County Health Department  
~~DDAGW, NWDO Correspondence File~~

ec: Linda S. Benham, Environmental Supervisor, DDAGW, NWDO  
Justin Bowerman, DOCC, DDAGW, NWDO