



**Environmental
Protection Agency**

John E. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



March 2, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Pastor Mark Bailey
Freewill Baptist Church
998 Laver Road
Mansfield, Ohio 44905

Richland County
Freewill Baptist Church
Transient Non-Community PWS
PWS ID: OH7055812
STU ID# 7061524

Dear Pastor Bailey:

This letter is notification that Freewill Baptist Church has not complied with requirements issued during this Agency's last survey performed on December 28, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code (OAC). You were notified in correspondence dated January 20, 2012, to respond in writing within 30 days, with time frames for compliance with the following requirements:

1. Develop a total coliform bacterial sample siting plan and forward a copy to Ohio EPA for review. A template was provided during the inspection. [OAC Rule 3745-81-21(A)]
2. Provide the information about the new cartridge filter that was requested in the January 20, 2012, letter. [OAC Rule 3745-91-02(A) and OAC Rule 3745-83-01(D)]
Additional action may be required after Ohio EPA's review of this information.
3. Replace the solid PVC cap currently on the top of the well casing with a cap that is specifically designed for wells. The well cap must have a down-turned screened vent. Connect the electrical conduit to the well cap through a sealed, screw-threaded connection. [OAC Rule 3745-09-05(P)]
4. Verify that the old well, located east of the church near the edge of the parking lot, has been properly abandoned and sealed. If it has not been properly abandoned and sealed, contract with a well driller to complete this work. Provide a copy of the Ohio Department of Natural Resources Sealing Report to this office. [OAC Rule 3745-9-10]

Respond in writing upon receipt of this letter with time frames for compliance with the above requirements.

Pastor Mark Bailey
March 2, 2012
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please contact me at 419-373-3102 or via email at Kim.Burnham@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: McGhee's Technical Water Service, Inc.
Richland County Health Department
DDAGW, Operations CO
DDAGW, NWDO File