




**Environmental Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



February 28, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Ms. Julie Vantaggi  
Mohican River Estates  
6 Corporation Center  
Broadview Heights, Ohio 44147

Ashland County  
Mohican River Estates  
Community PWS

PWS ID: OH0301312

Dear Ms. Vantaggi:

The Public Water System serving Mohican River Estates is in violation of the *Ohio Administrative Code (OAC) 3745-82-02* for failure to maintain the secondary maximum contaminant level for manganese. According to the Mohican River Estates monthly operating report submitted for January 2012, the finished water quality sample exceeded the secondary maximum contaminant levels (SMCL) for manganese. Each exceedance is a violation of *OAC 3745-82-02*.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by *OAC 3745-83-01 (F)(6)* to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions, please contact me at 419-373-3107 or at [elizabeth.ames@epa.state.oh.us](mailto:elizabeth.ames@epa.state.oh.us).

Sincerely,

Elizabeth Ames  
Division of Drinking and Ground Waters

//lr

pc: DDAGW – NWDO

