




**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nafly, **Director**



NOTICE OF VIOLATION – ACTION REQUIRED

Re: Hancock County
ODOT Rest Area 1-25 NB
TNC Water System
PWS ID# 3243812
STU ID# 3254855

February 27, 2012

Mr. Kirk Slusher, District Deputy Director
ODOT- District 1
1885 North McCullough Street
Lima, Ohio 45802

Dear Mr. Slusher:

ODOT Rest Area 1-25 NB public water system is in violation of Ohio Revised Code Chapter 6109 by failing to comply with the operational requirements of Ohio Administrative Code (OAC) 3745-83-01 during the month of January 2012.

ODOT Rest Area 1-25 NB public water system failed to maintain the daily minimum required (free/combined) chlorine residual in the distribution system. There were 5 days during the month in which the minimum chlorine residual was not maintained.

ODOT Rest Area 1-25 NB must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/lr

pc: Hancock County Health Department
DDAGW – NWDO
ec: Ann Scott, IFM
Tony Lotz, Facilities Manager

