



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



February 16, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Jim Hemrick
Country Acres Golf Club
17374 State Route 694
Ottawa, Ohio 45875

Putnam County
Country Acres Golf Club
Community PWS

PWS ID: OH6901412

Dear Mr. Hemrick:

The Public Water System serving Country Acres Golf Club is in violation of the Ohio Administrative Code (OAC) for failure to submit the following Monthly Operating Report(s) (MOR) required by OAC 3745-83-01 (I) and/or OAC 3745-81-75.

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the plant January 21 and 26 and in the distribution system January 1, 8, 17, 18, 19, 20, 21, 22, 28 and 29.

Chlorine for Community PWS (frequency and concentration)

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. OAC Rule 3745-83-01(G) (1) & (2) requires the public water system owner to monitor both the free and combined chlorine residuals at least once every day.

If you have any questions, please contact me at 419-373-3007.

Sincerely,

Clayton McKee
Division of Drinking and Ground Waters

//lr

pc: DDAGW - NWDO

