



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



February 16, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Lonnie C. Falknor
ODOT Rest Area 7-33 EB
1001 St. Marys Avenue
Sidney, Ohio 45365

Auglaize County
ODOT Rest Area 7-33 EB
Transient Non-Community PWS

PWS ID: OH0634012

Dear Mr. Falknor:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system January 7, 8, 26, 27, 28, 29, 30 and 31.

Chlorine for Community PWS (frequency and concentration)

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. OAC Rule 3745-83-01(G) (1) & (2) requires the public water system owner to monitor both the free and combined chlorine residuals at least once every day.

If you have any questions, please contact me at 419-373-3007.

Sincerely,

Clayton McKee
Division of Drinking and Ground Waters

/llr

pc: DDAGW – NWDO File

