



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 25, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Robert E. Hall
Woody Ridge Golf Course
6362 State Route 598
Shelby, Ohio 44875

Crawford County
Woody Ridge Golf Course
Transient Non-Community PWS

PWS ID: OH1735312

Dear Mr. Hall:

On August 29, 2011, I received a completed bacteria sample siting plan (plan) from you in response to my July 28, 2011 report regarding the July 12, 2011 sanitary survey of the Woody Ridge Golf Course's public water system.

The survey report included two requirements. Following is a summary of your responses to these requirements:

1. A completed bacterial sample siting plan was specified by Requirement 1. It appears that the plan you mailed to me is the original. I have made a copy for our files and have enclosed the original for your records.
2. Requirement 2 required the creation of an air gap where the filter backwash discharge line drains into the floor drain.

No written response was received concerning this requirement.

Failure to respond in Writing within 30 days


This letter is notification that the Woody Ridge Golf Course has not complied with a requirement issued during this Agency's last survey performed on July 12, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated July 28, 2011, to respond in writing no later than 30 days, with time frames for creating an air gap where the filter backwash discharge line drains into the floor drain.

Mr. Robert E. Hall
January 25, 2012
Page 2

Upon receipt of this letter, create an air gap where the filter backwash discharge line drains into the floor drain. Provide written verification that this work has been completed.

Please be advised that my colleague, Janis D'Amico has recently taken over responsibility for public water systems in Crawford County. If you have any questions regarding this letter, or any other matter involving your water system, please contact Ms. D'Amico at 419-373-3108 or via email at Janis.Damico@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Crawford County Health Department
Andy Barienbrock, DDAGW, Operations CO
DDAGW, NWDO File

ec: Janis D'Amico, DDAGW, NWDO