



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 27, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Pastor and Council
St. Paul's Reformed Church in America
6077 German Church Road
Ohio City, Ohio 45874

Van Wert County
St. Paul's Reformed Church in America
Transient Non-Community PWS
PWS ID: OH8134712
STU ID# 8159451

Dear Pastor and Council:


This letter is notification that St. Paul's Reformed Church in America has not complied with requirements issued during this Agency's last survey performed on August 18, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code (OAC). The church was notified in correspondence dated September 1, 2011, to respond in writing within 30 days, with time frames for compliance with the following requirements:

1. Extend the well casing the next time the well is worked on so that at least 12" of casing extends above grade. [OAC Rule 3745-95-05(O)]
2. To prevent the possibility of cross-contamination from the church's waste water system, provide an air gap where the water softener backwash discharge lines drain into the waste water plumbing or install another backflow prevention device. [OAC Rule 3745-95]

Respond in writing upon receipt of this letter with time frames for compliance with the above requirements.

If you have any questions please contact me at 419-373-3102.

Sincerely,


Kimberly K. Burnham, R.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

pc: Ronald Kill, Trustee
Van Wert County Health Department
DDAGW, Operations CO
DDAGW, NWDO File

