



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 27, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Jesse Chapa, Facilities/Transportation
Coordinator
Teaching & Mentoring Communities
- Ohio Regional Office
601 North Stone Street
Fremont, Ohio 43420-0186

Sandusky County
Helena Migrant Head Start Center

Transient Non-Community PWS
PWS ID: OH7256912

Dear Mr. Chapa:

This letter is notification that Teaching & Mentoring Communities has not complied with requirements issued during this Agency's last survey of the Helena Migrant Head Start Center, performed on October 27, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code (OAC). The organization was notified in correspondence dated November 4, 2011, to respond in writing within 30 days, with time frames for compliance with the following requirement:

1. Replace the existing unvented well cap with a cap that has a down-turned screened vent. Connect the electrical conduit to the well cap through a sealed, screw-threaded connection [OAC Rule 3745-09-05(P)].

Respond in writing upon receipt of this letter with a time frame for compliance with the above requirement.

Please be advised that my colleague, Janis D'Amico has recently taken over responsibility for public water systems in Sandusky County. If you have any questions regarding this letter, or any other matter involving your water system, please contact Ms. D'Amico at 419-373-3108 or via email at Janis.Damico@epa.state.oh.us.

Sincerely,

Kimberly K. Burnham, R.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

/lr

pc: Sandusky County Health Department
DDAGW, Operations CO
DDAGW, NWDO File

ec: Janis D'Amico

