



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 17, 2011

Patrick Brooks, P.E.
United McGill Corporation
1777 Refugee Road
Columbus, OH 43207

**Re: No Exposure Inspection Verification, Permit Number 4GRN00287*DG
United McGill Corporation**

Dear Mr. Brooks:

This letter is written regarding a follow-up storm water investigation I conducted at your facility on May 6, 2011. The purpose of the inspection was to verify compliance with your No-Exposure Exemption (NOE) in accordance with Ohio EPA's Storm Water Program.

Based on my observations, I noted that you addressed the issues from my previous letter. Drums and barrels that were stored outside are either now stored inside a building or removed from your property. The trench drains were removed and the trenches filled in with gravel. The fuel tank is under roof with secondary containment.

Thank you for addressing these issues. Your facility is in compliance with your No Exposure Certification. If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO
Scott Shields, City of Columbus
Nick Nespeca, United McGill Corporation

GS/nsm NOE letter_United McGill Corp, March 21, 2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

