



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 9, 2011

Pastor Virgil Phillips
House of Blessings Worship Center
3633 Big Run South Road
Grove City, OH 43123

**Re: Notice of Violation
House of Blessings Worship Center / Franklin County**

Dear Pastor Phillips:

This letter is written in follow up to a construction storm water inspection that I conducted at the House of Blessings Worship Center located at 3633 Big Run South Road on April 27, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. Please consider this a formal notice of violation. During the inspection, the following was noted:

Sediment and Erosion Controls:

- Most of the site around the building was barren. Be aware the General Permit states that all barren areas including stockpiles which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. The site appeared to be near final grade and there was no active construction activity. Please see attached pictures.
- Please install and maintain silt fence on the down slope of the construction site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,


Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm House of Blessings Worship Center, April 27, 2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov



House of Blessings Worship Center
Stabilize barren areas
Install silt fence
Scioto River Watershed
April 27, 2011
Photo by: Greg Sanders



House of Blessings Worship Center
Stabilize barren areas
Install silt fence
Scioto River Watershed
April 27, 2011
Photo by: Greg Sanders



