



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 6, 2011

Justin Loesch
City of Columbus Recreation and Parks Dept.
111 East Broad, Suite 101
Columbus, OH 43205

**Re: Indian Mound Park / Franklin County
Construction Storm Water Permit 4GC03322*AG**

Dear Mr. Loesch:

This letter is written in follow-up to a construction storm water inspection that I conducted at Indian Mound Park, located at 3901 Parsons Avenue, Columbus, Ohio, on March 31, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issue associated with construction activities at this site:

- Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within 7 days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within 7 days. A small portion of the site was barren. Please stabilize the site. Please see attached pictures.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosure


c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Indian Mound Park, March 31, 2011



6 4 1 2 3 4 5 6 7 8 9 10 11 12

**Indian Mound Park
Stabilize barren areas
Scioto River Watershed
March 31, 2011
Photo by: Greg Sanders**



**Indian Mound Park
Will need to re-seed
Scioto River Watershed
March 31, 2011
Photo by: Greg Sanders**



