



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 6, 2011

Bill Cashman  
Greenwood II LLC.  
1748 US Highway 42 North  
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Ohio Mulch / Delaware County  
Permit Number: 4GCO00012\*AG**

Dear Mr. Cashman:

This letter is written regarding the storm water inspection; I conducted at **Ohio Mulch** located **on North East of US 42 and Shortcut Road Intersection**, Delaware on March 16, 2011. The Agency understands that these construction activities are currently covered under the *General Storm Water Permit Associated with Construction Activities*. Based on the site inspection and the General Storm Water Permit, the following items were noted:


**Sediment Erosion Controls:**

- The perimeter controls require maintenance.
- I noted areas of rill erosion which requires repair, especially along the slopes near the silt fence.
- The permanent water quality out to the sediment pond must be removed and replaced with the temporary sediment control structure.
- Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. ***Given the time of year, a crimped mulch cover or equivalent is expected in preparation for the upcoming winter months.*** Portions of the site were addressed; however there were significant areas which require additional stabilization.

Bill Cashman  
Greenwood II LLC.  
Page -2-

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor

HK/nsm Ohio Mulch Delaware 3-16-2011