



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 26, 2010

Jerry Brems
Licking County
20 South Second Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at Etna Parkway / Licking County
Permit Number: 4GC03129*AG**

Dear Mr. Brems:

This letter is written regarding the storm water inspection I conducted at **Etna Parkway** located between US 40 & State Route 16 in Pataskala, Ohio on July 27, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- During the inspection, I evaluated the recently installed rock check dams within the drainage ditches associated with this project. The rock check dams have been replaced in accordance with my last inspection report.
- Please ensure the sediment basins are installed in accordance with the SWPPP. Weekly inspections are mandated under the permit to ensure the basins function.
- All barren areas which remain idle in excess of 21 days must be protected from erosion. Considerations must be made at this time to ensure all barren areas are protected, seeded and mulched prior to the onset of the upcoming winter months.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm ETNA Parkway, 8-27-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

