



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Wazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 26, 2010

Greg Zellars
Badrivishal LLC
600 Enterprise Drive
Lewis Center, OH 43035

**Re: Construction Storm Water Inspection at Holiday Inn Express / Delaware County
Permit Number 4GC02874*AG**

Dear Mr. Zellars:

This letter is written in follow-up to our joint construction storm water inspection at 2010 Polaris Parkway, Columbus, Ohio on June 30 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The centralized sediment basin is completed. The temporary riser is installed. However, the temporary riser is not properly sealed to the outlet structure, thus eliminating the intended function. Corrective measures are expected within three days of receipt of this letter to seal the outlet structure to the temporary riser to ensure effective sediment control for this site

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Holiday Inn Express Polaris Pkwy 6-30-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

