



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 24, 2010

Michael Burger
Danis Building Construction Company
2715 Tuller Parkway Drive
Dublin, OH 43017

**Re: Construction Storm Water Inspection at USFPO Warehouse-DSCC Facility
Franklin County
Permit Number 4GC03187*AG**

Dear Mr. Burger:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley and Mike Shields of Ohio EPA at USFPO Warehouse-DSCC Facility located at 3990 East Broad Street, Ohio on August 11, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. The following was noted:

Sediment and Erosion Control:

- The construction entrance and exit ways off of Eighth Boulevard require better controls to keep the road clear of sediment (Figure 1). Please install high traffic controls to this area to avoid further off site vehicle tracking.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm USFPO Warehouse DSCC Facility 8-11-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





Figure 1: Roadway obstructed by sediment tracked off site

