



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 24, 2010

Stephen Martin  
7991 Columbus Pike LLC  
50 North Sandusky Street  
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Orange Corporate Center  
Delaware County  
Permit Number: 4GCO00006\*AG**

Dear Mr. Martin:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Megan Reising of the Ohio EPA at Orange Corporate Center located at 7991 Columbus Pike on August 9, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The inlet protections on the storm water catch basins appeared to have holes and will need to be replaced to maintain their sediment control function.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Orange Corporate Center 8-9-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

