



State of Ohio Environmental Protection Agency

PHYSICAL ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 24, 2010

Ken Richardson
City of Dublin
5800 Shier Rings Road
Dublin, OH 43016

**Re: Construction Storm Water Inspection at UNI-161-12.98 Industrial Parkway / Union County
Permit Number: 4GC03121*AG**

Dear Mr. Richardson:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Megan Reising of the Ohio EPA at UNI-161-12.98 Industrial Parkway located at the intersection of State Route 161 and Industrial Parkway in Dublin, Ohio on August 9, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- The storm sewer on the north side of SR 161, across the street from the water tower, is impacted with sediment. Please install sediment controls to minimize off-site sediment transport.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm UNI 161 12.68 Industrial Parkway, 8-9-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director









Figure 1: Sediment in Outlet Pipe



Bill Dorman
Village of New Albany
Page -2-

- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 24, 2010

Bill Dorman
Village of New Albany
7800 Bevelhymer Road
P.O. Box 188
New Albany, OH 43054

**Re: Storm Water Inspection at US 62 (Johnstown Road) / CR 18
(Central College Road) Intersection Improvements / Franklin County
Permit No: 4GC03076*AG**

Dear Mr. Dorman:

This letter is written in follow-up to a construction storm water inspection by Stephen Riley and Michael Shields, of the Ohio EPA, conducted at US 62 (Johnstown Road) / CR 18 (Central College Road) Intersection Improvements on August 9, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. It appeared during the inspection that construction activity is near completion. A Notice of Termination will be required provided the following requirements are met.

- During the inspection our staff noticed barren areas around the intersection. Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

