OhioEPA
State of Ohio Environmental Protection Agency

STREET ADDRESS:
Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office
TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:
P.O. Box 1049
Columbus, OH 43216-1049

August 23, 2010

Mark Richard
City of Columbus- Design & Construction
109 North Front Street - 3rd Floor
Columbus OH 43215

Re: Construction Storm Water Inspection at Hayden Run Road & Leppert Road Improvements / Franklin County
Permit Number: 4GC03188*AG

Dear Mr. Richard:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA, at **Hayden Run Road & Leppert Road Improvements** located at intersection of Hayden Road and Leppert Road in Columbus, Ohio on August 11, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- It appears all sediment and erosion controls were in place, and are functioning as intended. Please continue to maintain all controls to ensure continued compliance with the requirements of your General Storm Water Permit.

Maintenance:

- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Hayden Run Road & Leppert Road Imp 8-11-10