



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 23, 2010

Adam Stout  
US Bridge  
201 Wheeling Avenue  
Cambridge, OH 43725

**Re: Storm Water Inspection at Big Run Road Pedestrian Bridge / Knox County  
Permit No: 4GC03179\*AG**

Dear Mr. Stout:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley and Michael Shields of Ohio EPA at the Big Run Road Pedestrian Bridge located on Big Run Road at the Kokosing River on August 09, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. The following was noted:

**Sediment and Erosion Control:**

- The sediment and erosion controls along the north side of the project area, adjacent to the Kokosing River, is in disrepair and requires maintenance. Please repair these controls to avoid uncontrolled discharges to waters of the state (see figure 1).
- Please be aware the general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches to ensure continued effectiveness of the sediment basin.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Adam Stout  
US Bridge  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Big Run road Pedestrian Bridge 8-9-2010