



State of Ohio Environmental Protection Agency

RECEIPT ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 24, 2010

Robin Green  
Hidden Creek LTD  
PO Box 253  
West Jefferson, OH 43162

**Re: Storm Water Inspection at Hidden Creek, Phase V / Madison County  
Permit No: 4GCD00008\*AG**

Dear Ms. Green:

This letter is written in follow-up to a construction storm water inspection by Elizabeth Schaller and Megan Reising of the Ohio EPA conducted at Hidden Creek, Phase V located east of Olmstead Road, south of Kouisville Road and opposite Thomas Lane in West Jefferson, Ohio on July 28, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- All lots are developed.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:  
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:  
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Robin Green  
Hidden Creek LTD  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Hidden Creek Phase V, 7-28-10