



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 23, 2010

Shane Clark  
Del-Co Water Co. Inc.  
6658 Olentangy River Road  
Delaware, OH 43015

**Re: Storm Water Inspection at Del -Co Water Line Improvement Project March  
2009 / Delaware County  
Permit No: 4GC03032 \*AG**

Dear Mr. Clark:

This letter is written in follow up to a construction storm water inspection by Abigail Tamkin and Michael Shields of the Ohio EPA conducted at Del-Co Water Line Improvement Project March 2009 located in Delaware County on August 9, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities.

It appeared during the inspection that construction activity is completed for this site. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:

<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.


- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:  
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Shane Clark  
Del-Co Water Co. Inc.  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Del Co Water Line Improvement Project March 2009 8-9-2010