



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 23, 2010

Clyde Seidel  
City of Hilliard  
3800 Municipal Way  
Hilliard, OH 43026

**Re: Construction Storm Water Inspection at Avery Road & Northwest Parkway  
Franklin County.  
Permit Number: 4GC03177\*AG**

Dear Mr. Seidel:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at **Avery Road & Northwest Parkway** located in Columbus, Ohio on August 11, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

**Sediment and Erosion Controls:**

- The inlet protection located on the southwest portion of the project has failed to minimize sediment runoff into the storm sewer located on the site. Corrective measures are expected within three days from receipt of this letter (Figure 1).

**Maintenance:**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Clyde Seidel  
City of Hilliard  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm Avery Road & Northwest Parkway 8-11-2010



**Avery Road & Northwest Pkwy  
Scioto River Watershed**

**Photo by: Vinod Tujalpuram/ Abigail Tamkin  
Date: 08-11-2010**

**Figure 1: Inlet protection has failed.**

