



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 19, 2010

Chris Henderson  
Ohio State University  
Facilities Planning Department  
Central Classroom Bldg  
2009 Millikin Road  
Columbus, OH 43210

**Re: Construction Storm Water Inspection at OSU Fawcett Center/Franklin County.  
Permit Number: 4GC03287\*AG**

Dear Mr. Henderson:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram of Ohio EPA at **OSU Fawcett Center** located 2400 Olentangy River Road Columbus, Ohio on August 05, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

**Sediment and Erosion Controls:**

- It appears all sediment and erosion controls were in place, and are functioning as intended. Please continue to maintain all controls to ensure continued compliance with the requirements of your General Storm Water Permit.

**Maintenance:**

- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO