



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

August 18, 2010

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

Brian Willis
Thomas D Phillips III
1719 North Cassady Avenue
Columbus, OH 43219

**Re: Construction Storm Water Inspection at Phillips Property #010-122683 & 010-122684
Franklin County
Permit Number: 4GC02925*AG**

Dear Mr. Willis:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Vinod Tujalpuram of the Ohio EPA at the Phillips Property Parcels #010-122683 & 010-122684 located south of the intersection of North Cassady Avenue and Agler Road in Columbus, Ohio on July 28, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The silt fence around the property appeared to be in poor condition and requires maintenance.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Phillips Property Parcels 7-28-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





4GC0297720100816

2010/08/16

4GC02977

JESUS POWER ASSEMBLY OF GOD



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 17, 2010

Jack Berry
Midwest Church Design Ltd.
634 Eckel Road
Perrysburg, OH 43551

**Re: Storm Water Inspection at Jesus Power Assembly of God/ Franklin County
Permit No: 4GC02977*AG**

Dear Mr. Berry:

This letter is written in follow-up to a construction storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of the Ohio EPA, at the Jesus Power Assembly of God located at 5215 Cleveland Avenue Columbus, on July 28, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

- All inlet protections must be covered appropriately to address the sediment runoff into the storm sewers located on the site.

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Jack Berry
Midwest Church Design Ltd.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Jesus Power Assembly of God, 7-28-2010