



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 12, 2010

Robert A Corley
Aarons Inc.
309 E Paces Ferry Rd NE 8th FL
Atlanta, GA 30305

**Re: Storm Water Inspection at Aarons-Marysville / Union County
Permit No: 4GC0313*AG**

Dear Mr. Corley:

This letter is written in follow-up to a construction storm water inspection by Megan Reising and Abigail Tamkin of the Ohio EPA conducted at Aarons located at 1051 Lydia Drive in Marysville, Ohio on August 4, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities.

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Robert A Corley
Aarons Inc.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Aarons-Marysville 8-4-2010



4GC0319020100811

2010/08/11

4GC03190

Z & H GROVE CITY STORAGE PROPERTIES



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 12, 2010

M Zachery Zeune
MZ Construction & Development LLC
7509 East Main Street Suite 216
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Z & H Grove City Storage Properties
Franklin County
Permit Number: 4GC03190*AG**

Dear Mr. Zeune:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Michael Shields of the Ohio EPA at Z & H Grove City Storage Properties located at 3170 Urbancrest Industrial Drive on August 2, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appeared the site had just been cleared of vegetation and that silt fence was being installed. Please continue to implement your Storm Water Pollution Prevention Plan.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

cc: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Z&H Grove City Storage 8-2-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



