



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 11, 2010

Brian Boyd
Joe Dirt
2410 Performance Way
Columbus, Ohio 43207

**Re: Construction Storm Water Inspection at Windsor Avenue Parcel D10-263045 /
Franklin County.
Permit Number: 4GC02992*AG**

Dear Mr. Boyd:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at Windsor Avenue Parcel D10-263045 located 1000 Feet East of Intersection of Joyce and Winsor Road, Columbus on July 28, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- The silt fence must be established along the perimeters of the project.
- It is my understanding, a few stockpiles located on the project are not seeded. Please ensure all stockpiles located on the site are protected from erosion to meet the requirements of your General Permit.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Brian Boyd
Joe Dirt
Page -2-

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO