





**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Re: Hancock County
Lakeland Golf Course - Fostoria
TNC Water System
PWS ID # OH3236412

March 16, 2012

Mr. Jonathan Moyer
Lakeland Golf Course Fostoria
3770 County Road 23
Fostoria, Ohio 44830

Dear Mr. Moyer:

This letter will confirm removal of the water use advisory required in our letter dated October 28, 2011. This is based on one set of four total coliform negative (safe) samples collected March 12, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of March 2012.

Yours truly,

Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

pc: Hancock County Health Department
DDAGW, NWDO

