



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Garzarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 11, 2010

Jason Francis
M/I Homes of Central Ohio, LLC
3 Easton Oval, Suite 340
Columbus, OH 43219

**Re: Construction Storm Water Inspection at Pinnacle Club (Subdivision English Turn Drive)
(The Greens) / Franklin County
Permit Number: 4GC03151*AG**

Dear Mr. Francis:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Michael Shields of the Ohio EPA at Pinnacle Club (Subdivision English Turn Drive) located between I-71 and Buckeye Parkway in Grove City, Ohio on August 2, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please inspect the storm drains in the area of the construction project to ensure that inlet protections are installed and are in good condition. Several exposed storm drains were noted, as well as several with damaged covers.
- The silt fence around the project appeared to be in good condition, as did the sediment pond and the associated temporary riser.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Pinnacle Club Subdivision English Turn Drive (The Greens) 8-2-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director







State of Ohio Environmental Protection Agency

STREET ADDRESS:

Garzarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 11, 2010

Jason Francis
M/I Homes of Central Ohio, LLC
3 Easton Oval, Suite 340
Columbus, OH 43219

**Re: Construction Storm Water Inspection at Pinnacle Club (Subdivision English Turn Drive)
(The Greens) / Franklin County
Permit Number: 4GC03151*AG**

Dear Mr. Francis:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Michael Shields of the Ohio EPA at Pinnacle Club (Subdivision English Turn Drive) located between I-71 and Buckeye Parkway in Grove City, Ohio on August 2, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please inspect the storm drains in the area of the construction project to ensure that inlet protections are installed and are in good condition. Several exposed storm drains were noted, as well as several with damaged covers.
- The silt fence around the project appeared to be in good condition, as did the sediment pond and the associated temporary riser.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Pinnacle Club Subdivision English Turn Drive (The Greens) 8-2-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

