



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

W. Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 09, 2010

Aldino Stazzone  
OSU- Facilities Design & Construction  
2009 Millikin Road (400 Central Classroom Bldg)  
Columbus, OH 43210

**Re: Construction Storm Water Inspection at OSU Medical Center Improvements (Medium Voltage Part 1) and OSU Medical Center Improvements  
Franklin County  
Permit Number: 4GC03171\*AG & 4GC03058\*AG**

Dear Mr. Stazzone:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram of Ohio EPA at OSU Medical Center Improvement (Medium Voltage Part 1) and OSU Medical Center Improvements located at 1654 Upham Drive in Columbus Ohio on August 02, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

**Sediment and Erosion Controls:**

- It appears all sediment and erosion controls are in place and functioning as intended. Please continue to maintain all sediment controls at all phases of construction to meet the requirements of your General Storm Water Permit.

**Maintenance:**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO