



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

W. S. Zarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 9, 2010

John Igel
Bishop Hartley High School
1285 Zettler Road
Columbus, OH 43227

**Re: General Storm Water Permit for Bishop Hartley High School
Franklin County
Permit No: 4GC03054 *AG**

Dear Mr. Igel:

It is my understanding that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Bishop Harley High School

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Koreski, Director

