



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Garzarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 09, 2010

Khaled Farag  
Silver Development  
2641 Bethel Road  
Columbus, OH 43220

**Re: Construction Storm Water Inspection at Noor Square  
Franklin County  
Permit No: 4GC03077\*AG**

Dear Mr. Farag:

This letter is written in follow-up to a construction storm water inspection conducted by Vinod Tujalpuram of the Ohio EPA, at Noor Square located at 5163 Wilcox Road Columbus, Ohio on August 2, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- All perimeter controls must be maintained until final completion of the project. Please ensure appropriate controls are installed to minimize sediment run-off onto adjacent properties.
- In my understanding, the inlet protections are covered by Asphalt at this time, and will require maintenance with 3 days from receipt of this letter.
- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:  
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:  
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

Khaled Farag  
Silver Development  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Noor Square 8-2-10