



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 30, 2010

Tim Hansley
City of Pickerington
100 Lockville Road
Pickerington, OH 43147

**Re: Storm Water Inspection at Storm Sewer and Water Main Construction for
Olde Pickerington / Fairfield County.
Permit Number: 4GC03039*AG**

Dear Mr. Hansley:

This letter is written in follow-up to a construction storm water inspection by Stephen Riley and Elizabeth Schaller of the Ohio EPA conducted at the Storm Sewer and Water Main Construction for Olde Pickerington located at Church, Center, East, Fanchers and Town Square Drives on July 27, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is nearly complete for this site and all disturbed areas are in the process of being permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- During the inspection our staff took notice of the sediment and erosion controls for the storm water inlets. These controls lack sufficient height to insure the encroaching sediment does not spill into the storm water inlets (Figure 1). Please replace these controls with measures of greater height to avoid sediment discharges to waters of the state.
- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director




Tim Hansley
City of Pickerington
Page -2-

practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Storm Sewer and Water Main construction for Olde Pickerington 7-27-2010




Figure 1: Insufficient controls around storm water inlet

