



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 4, 2010

Steve Geiger
Geiger Excavating Inc.
65 Southwind Drive
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Bedford II Landfill Cover
Franklin County.
Permit Number: 4GC03047*AG**

Dear Mr. Geiger:

This letter is written regarding the storm water inspection conducted by Elizabeth Schaller and Stephen Riley of Ohio EPA at Bedford II Landfill Cover located at Enterprise Drive in Gahanna, Ohio on July 26, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- Water collection inlets must be covered to minimize sediment flow off-site. (see figure 1).
- Skimmer must be maintained after storm events to ensure functionality. This was brought to your attention during our last inspection on April 7, 2010.

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on-site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Steve Geiger
Geiger Excavating Inc.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO




Figure 1: Sediment laden waters leaving property, skimmer also requires maintenance.

