



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Zarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 29, 2010

Ed Rainaldi
SB43 Properties LLC
1160 Kames Way Drive
New Albany, OH 43054

**Re: Storm Water Inspection at the Paine Building / Franklin County
Permit No: 4GC03104*AG**

Dear Mr. Rainaldi:

This letter is written in follow-up to a construction storm water inspection by Elizabeth Schaller and Stephen Riley of the Ohio EPA, conducted at the Paine Building located at 1655 and 1675 Eastgate Parkway in Gahanna, OH on July 26, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Please remove the inlet protections in your parking lots and retention pond outlet, as they are no longer needed.
- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%. This is especially important near the retention pond.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Ed Rainaldi
SB43 Properties LLC
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Paine Building 7-26-2010